



VIOLATION NOTICE

CITY OF PHILADELPHIA

DEPARTMENT OF LICENSES & INSPECTIONS
PUBLIC SERVICE CONCOURSE
MUNICIPAL SERVICES BUILDING, PHILADELPHIA, PA. 19107

APRIL 6, 1989

32687

48 - 60 Laurel Street

PREMISES
IN
VIOLATION

Page 2

An inspection of the above premises reveals conditions which are in violation of the Philadelphia Code of General Ordinances, as specified below. Your name appears on official records as the owner, agent or other responsible party for the premises found to be in violation. Failure to correct these conditions within the specified time of this notice will result in prosecution. If title has been transferred please furnish proof of transfer to L & I Central Clerical, Public Service Concourse, Municipal Services Building, 15th Street & J. F. Kennedy Boulevard, Philadelphia, Pa. 19107. The Department does not authorize anyone to solicit any work for services which may be required by this notice.

Violations which do not have a specific location shown apply to the entire premises.

For information on the violations, contact:

Any violation on this notice apply to the Board of License and Inspection Review, Room 710 Municipal Services Building, Philadelphia, Pa. 19107 within 10 days of this notice. It is required to submit a copy of this notice with the appeal.

SECTION 5-507

VIOLATION

504 Clean entire premises. This work can be only done by an approved contractor. This building is to be vacated IMMEDIATELY 1st and 2nd floors & yard

5-1402(f) 1. (b) Reg. 01 Provide one approved portable fire extinguisher with a minimum rating of 2-A for every 2500 square feet of floor space per floor. 2nd floor

5-1402(1)3.(a)Reg. 05 Provide one approved portable fire extinguisher with a minimum rating of C. 2nd floor - Lab and storage

5-1403(1) 16 Repair fire door 2nd floor

5-1302(1) & (3) 36 Provide sufficient aisles for emergency egress 1st floor - Storage Room and Shop

5-3102(2) 25 Thoroughly clean building All floors

1605(1)(a) 74 Provide electrical equipment and wiring in accordance with the National Electrical Code in areas within the possible path of flammable vapor travel. 2nd floor - Lab

5-1601(11) 91 Provide two exits, one of which shall be remote from storage of flammable and class II and IIIA combustible liquids. 2nd floor - Lab

Cont

(Rev. 12-84)

100058